

INDUSTRIAL FIRE SERVICES

Gwaipara Road, Near Patna Institute,
Jugsalai, Jamshedpur-831006

Mob. : 9973678733, 8825240629
9155685104, 9570027827

E-mail : industrialfire01@gmail.com
GSTIN : 20AAGFI2712P1Z1
Trad Licence No : JUG702061964189

Specialist in : All types of Fire extinguisher, Automatic Fire extinguisher, Refilling of ABC Stored pressure type fire extinguisher, Refilling & Servicing of cartridge type fire extinguisher, Automatic Fire extinguisher, Installing Fire Detection System with Control Panel Hydrant System.

Ref. No. : IFS/TC/2021-22

Date : 07.08.2021

TEST / REFILLING CERTIFICATE

To,

M/S SWAMI VIVEKANANDA
COLLAGE OF EDUCATION, Salbani, Jharkhand

Sl. No.	Items	Capacity	Quantity
1.	Water co ₂ fire extinguisher	_____	_____
2.	M. Foam fire extinguisher	9 Ltrs	1 No. _____
3.	Dry powder cartridge operated Fire Extinguisher(BC)	5 KG	2 No. _____
4.	ABC/BC stored pressure operated Fire Extinguisher	6 KG	5 No. _____
5.	Co ₂ fire extinguisher	_____	_____

WARRANTY ABC BASED FIRE EXTINGUISHERS

The above fire extinguisher are using condition from 07.08.2021 to 06.08.2023

The above mentioned good are warranted against defect in material and workmanship under normal use. The company's obligation shall be limited to rectifying, repairing or replacing defective parts Ex-factory, provided the purchaser has given written notice within seven days form date of receipt of goods. The company will be automatically relieved of its obligation in case the unit is opened or any changes/repairs are made without its prior approval within the warranty period. This warranty excludes any and every other obligation for loss or damage direct or consequential or for any accident resulting from defective and faulty workmanship.

WARRANTY CARTRIDGE BASED FIRE EXTINGUISHERS

- ❖ The above fire extinguisher should be checked at every quarter in a year & if the cartridge's weight is found 10-15% less from the punched weight, it should be refilled or replaced.
- ❖ We do not take any warranty for the performance of the stored pressure type product if the safety sil is broken, damage or tampered.

For INDUSTRIAL FIRE SERVICES

